



DEPARTMENT OF FINANCIAL SERVICES

Division of State Fire Marshal – Bureau of Fire Prevention

Fire Equipment Inspection Report

LICENSE INFORMATION

Company Name: _____ Phone Number: _____

Physical Location: _____ County: _____

License Number: _____ Type & Class Choose One

☐ Inspection ☐ Re-Inspection

☐ Passed ☐ Failed

Inspector Signature: _____ Date: _____

Responsible Person Signature: _____ Date: _____



DEPARTMENT OF FINANCIAL SERVICES
Division of State Fire Marshal – Bureau of Fire Prevention

Fire Equipment Inspection Report

☐ Mobile ☐ Facility

List all license numbers using this facility:

Minimum Equipment and Facilities Required

		License Class				Yes	No*	N/A
1.	Hydrostatic test equipment for high pressure testing and calibrated cylinder maintained in compliance with the requirements of CGA C-1, as adopted in Rule Chapter 69A-3, Florida Administrative Code. DOT certification letter posted on or near the test apparatus identifying a current retester ID# issued to the facility. RIN last date of issue: _____ RIN: _____	A				☐	☐	☐
2.	Equipment for test dating United States Department of Transportation specification cylinders. Die stamps for Class A and D facilities must be a minimum of ¼ inch and include the retester identification number issued to the facility.	A	B	C	D	☐	☐	☐
3.	Clock with sweep second hand or digital clock with second increments on or close to the hydrostatic test apparatus.	A	B	C	D	☐	☐	☐
4.	CO2 receiver – bulk, liquid or cascade system for proper filling of CO2 extinguishers.	A	B			☐	☐	☐
5.	Conductivity tester and tags are required by NFPA 10, as adopted in Rule Chapter 69A-3, Florida Administrative Code.	A	B	C	D	☐	☐	☐
6.	Drying method which does not exceed 150 degrees Fahrenheit for high and low pressure cylinders in accordance with NFPA 10, as adopted in Rule Chapter 69A-3, Florida Administrative Code and the manufacturer's specifications.	A	B	C	D	☐	☐	☐
7.	Proper wrenches with non-serrated jaws or valve puller, hydraulic or electric.	A	B	C	D	☐	☐	☐
8.	Appropriate inspection light.	A	B	C	D	☐	☐	☐
9.	Low pressure test apparatus for the licenses held, with gauges certified accurate in compliance with the requirements of CGA-C1 and maintained in accordance with the requirements of CGA-C1. FDOT certification letter posted on or near the test apparatus identifying the current retester ID# issued to the facility. RIN last date of issue: _____ RIN: _____	A	B	C	D	☐	☐	☐
10.	All record tags, service, hydro test, 6 year maintenance, as required by Rule 69A-21 and 49 CFR Parts 100-177, as adopted in Rule Chapter 69A-3 Florida Administrative Code.	A	B	C	D	☐	☐	☐
11.	Scales with division of not more than ¼ ounce with adequate weighing capacity for weighing CO2 cartridges, must be certified annually or tested for accuracy annually by a service agency in accordance with the provisions of Chapter 531, Florida Statutes.	A	B	C	D	☐	☐	☐
12.	Scales with adequate weighing capacity for extinguisher inspection and filling must be certified annually or tested for accuracy by a service agency in accordance with the provisions of Chapter 531, Florida Statutes.	A	B	C	D	☐	☐	☐



DEPARTMENT OF FINANCIAL SERVICES

Division of State Fire Marshal – Bureau of Fire Prevention

Fire Equipment Inspection Report – cont.

Minimum Equipment and Facilities Required

13.	Vise, 6 inch minimum (chain or bench).	A	B	C	D	☐	☐	☐
14.	Supply of chemicals in accordance with manufacture's specifications in proper storage for all extinguishers and systems being serviced.	A	B	C	D	☐	☐	☐
15.	Facilities for leak testing of pressurized extinguishers and pre-engineered system cylinders in accordance with the manufacture's specifications.	A	B	C	D	☐	☐	☐
16.	Pressure gauges shall be calibrated in accordance with Section 4-5.4.2, NFPA 10, as adopted in Rule Chapter 69A-3, Florida Administrative Code.	A	B	C	D	☐	☐	☐
17.	Adapters, fittings and equipment for properly servicing and/or recharging all extinguishers and pre-engineered systems cylinders being serviced and recharged.	A	B	C	D	☐	☐	☐
18.	Safety cage or barrier for hydrostatic testing of low-pressure cylinders.	A	B	C	D	☐	☐	☐
19.	Scales with divisions of not more than ½ pound and minimum 150 pounds for weighing chemical recharging. Must be certified annually or tested for accuracy annually in accordance with the provisions of Chapter 531, Florida Statutes.	A	B	C	D	☐	☐	☐
20.	Cable crimping tool (where required) for pre-engineered systems being installed and serviced in accordance with the manufacturer's specifications.				D	☐	☐	☐
21.	Cocking lever (where required) for pre-engineered systems being installed and serviced in accordance with the manufacturer's specifications.				D	☐	☐	☐
22.	Pipe vise, dies, reamer, etc. for pre-engineered systems being installed and serviced in accordance with the manufacturer's specifications.				D	☐	☐	☐
23.	Stock of supplies for extinguishers and/or pre-engineered systems being installed and serviced in accordance with the manufacturer's specifications.	A	B	C	D	☐	☐	☐
24.	Installation, maintenance and recharge manuals for extinguishers and pre-engineered systems being inspected, serviced and installed.	A	B	C	D	☐	☐	☐
25.	Closed recovery system for reusing dry chemical in accordance with NFPA 10, as adopted in Rule Chapter 69A-3, Florida Administrative Code.	A	B	C	D	☐	☐	☐
26.	NFPA 10 and NFPA 96, as adopted in Rule Chapter 69A-3, Florida Administrative Code, CGA C-1, C-6, C-6.1, C-6.3, CFR 49 parts 100-177 and CFR 29 parts 1900-1910, all as adopted in Rule Chapter 69A-3, Florida Administrative Code.	A	B	C		☐	☐	☐
27.	NFPA 12, 12A, 34, 17, 17A, 96, 2001, CGA C-1, C-6, C-6.1, C-6.3, CFR 49 parts 100-177 and CFR parts 1900-1910, all as adopted in Rule Chapter 69A-3, Florida Administrative Code.				D	☐	☐	☐
28.	Closed recovery system for removal and recharge of Halon as required in NFPA 10, as adopted in Rule Chapter 69A-3, Florida Administrative Code, or an exemption from the State Fire Marshal, as provided in Section 633.061(3), Florida Statutes. System Manufacturer: _____ System Serial Number: _____	A	B	C	D	☐	☐	☐
29.	Printed invoices completed in compliance with Section 69A-21.251, Florida Administrative Code.	A	B	C	D	☐	☐	☐
30.	System Inspection reports.				D	☐	☐	☐

*Note: Items checked "No" represent violations of Florida Statutes or Administrative Rules.

Any violation noted must be corrected immediately. A re-inspection will be conducted no later than the date designated below. Failure to comply may result in administrative action by the State Fire Marshal.

Correct by date: _____