

---

# **Florida Public Schools**

## Annual Fire Safety Report

**Alex Sink**  
Chief Financial Officer  
State Fire Marshal

Produced by  
Florida Division of State Fire Marshal

Prepared by the Bureau of Economic and Business Research  
University of Florida

---

# Table of Contents

---

Letter from the State Fire Marshal .....	3
Overview of Law .....	5
Inspection Summary .....	7

Dear Floridian,

This is the fourth annual report by the State Fire Marshal's Office on the status of fire safety inspections in Florida's public schools. This report covers the school year 2005-2006 and finds Florida's school districts and fire departments still need to work on improving inspection rates.

Florida law requires each local school district and each local fire department to annually inspect every public school and ancillary facility within each jurisdiction. I applaud those school districts and fire departments that did their duty under the law, but every school district and fire department must make school fire safety inspections a priority.

The goal of the State Fire Marshal's Office is to provide school districts and local fire officials with tools to ensure inspection reports are complete, consistent, and accurate. We have continually worked to improve the reporting system, including this year reducing the electronic report form to one page per school inspection to help make the process more efficient. By our estimate, filling out the new report should require about two minutes per school inspection.

This summary report has been provided to the Legislature and is available on the Division of State Fire Marshal's website at [www.fldfs.com/sfm](http://www.fldfs.com/sfm).

I know each of you is committed to doing your job well, so please commit now to making sure every school is inspected every year and that violations are appropriately addressed. Our children and our communities are depending on it.

Sincerely,

A handwritten signature in black ink that reads "Alex Sink". The signature is written in a cursive, flowing style.

Alex Sink  
Florida Chief Financial Officer  
State Fire Marshal



# Overview of Law

---

## Overview of the Requirements of Section 1013.12, Florida Statutes

The firesafety inspections referred to in the statute above are applicable to all buildings owned, leased, or being lease-purchased by the school board, including all permanent and re-locatable buildings. In addition, they must begin not sooner than one year after a new building has been occupied. They must be performed each fiscal year in accordance with any applicable code or standard, such as NFPA 101, as adopted in Rule 69A-3.012, Florida Administrative Code, or any other applicable code or standard which has been adopted in Rule Chapter 69A-58, Florida Administrative Code. Finally, the subject inspections are not applicable to new construction or new buildings which are subject to and controlled by Section 1013.38, Florida Statutes.

Each firesafety inspection report and plan of correction must contain, at a minimum, the name of the school district or community college, the name of the local fire authority having jurisdiction (that is, the municipality, county, or special district), the name of the facility inspected, the type of facility



inspected (that is, K-5, 6-9, 10-12, community colleges, other), the facility address, the number of the facility as listed in the Florida Inventory of School Houses (FISH#), the name, address, and phone number of each

inspector and the designation of whether such inspector is a special fire safety inspector or a municipal fire safety inspector, the date of the inspection, and each violation or deficiency noted during an inspection.

Reports of the inspections must be filed with the local school board and the local site administrator. A plan and schedule for correction of any deficiency in the inspection report must be developed by any fire safety

*Continued on page 6*

---

inspector finding a deficiency in conjunction with the school board and that plan and schedule then must be adopted and complied with by the school board.

Furthermore, each violation or deficiency report must contain the Building name or number and, if applicable, the room number of the building in which the violation was noted; a description of the violation or deficiency and the number of times this violation or deficiency has been cited. In addition, the estimated correction date, total number of violations or deficiencies cited not involving serious life safety hazards and the total number of violations or deficiencies cited involving serious life safety hazards. Finally, the date of the scheduled re-inspection, a statement that the district has or has not complied with 1013.12(1)(c), a statement that the local authority having jurisdiction has or has not complied with 1013.12(2) c), including verification that the required fire drills have been completed. The report must include the signature of the district inspector if the inspection was made by the school district, or the signature of the local fire official if the local authority having jurisdiction made the inspection. If joint inspections were performed, both the school district fire safety inspector and the local fire official must each sign the report.

When the violation or deficiency has been corrected, the school board must notify the division of such correction. The inspection reports noted above together with the plan and schedule for correction of any deficiency must be submitted to the division by June 30, of each year.

---

---

**Florida School District Inspections**

Total number of violations per Violation Group:

Building Services	No Violations Noted
Construction/Renovation	Operating Features
Elevator/Escalator/etc.	Outside Structure
Extinguishment	Protection
Fire Alarm	Rubbish/Laundry Chutes
General Requirements	Special Provisions
HVAC	Unknown Code Violation
Imminent Hazard	Utilities
Means of Egress	




# Inspection Summary (Statewide)

## Florida Local Fire Authority Inspections

Total number of schools and ancillary facilities	3,767
Number of school and facilities inspected	3,019
Percentage inspected	80%

Total number of violations per Violation Group:

Building Services	No Violations Noted
Construction/Renovation	Operating Features
Elevator/Escalator/etc.	Outside Structure
Extinguishment	Protection
Fire Alarm	Rubbish/Laundry Chutes
General Requirements	Special Provisions
HVAC	Unknown Code Violation
Imminent Hazard	Utilities
Means of Egress	



Percentage of Schools and Facilities Inspected by Local Fire Authorities



# Inspection Summary (County-by-County)

## Alachua

Total number of schools and ancillary facilities	67
School District	
Number of school and facilities inspected	67
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	67
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	206
Means of Egress	227
Protection	116
Fire Alarm	55
Extinguishment	43
Building Services	3
Utilities	256
HVAC	2
Operating Features	23
No Violations Noted	2
Unknown Code Violation	3

## Baker

Total number of schools and ancillary facilities	10
School District	
Number of school and facilities inspected	6
Percentage inspected	60%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
Violations Uncoded	

Fire safety inspection reports were not received for the following:

- Southside Education Center
- Baker Superintendent's Office
- Baker Support Services Facility
- Transportation Facility

# Inspection Summary (County-by-County)

Bay	
Total number of schools and ancillary facilities	45
School District	
Number of school and facilities inspected	43
Percentage inspected	96%
Local Fire Authority	
Number of school and facilities inspected	9
Percentage inspected	20%
Total number of violations per Violation Group:	Count
Imminent Hazard	6
General Requirements	128
Means of Egress	534
Protection	19
Fire Alarm	120
Extinguishment	570
Building Services	6
Utilities	259
HVAC	6
Rubbish/Laundry Chutes	3
Operating Features	15
Outside Structure	2
Construction/Renovation	2
Unknown Code Violation	4
Fire safety inspection reports were not received for the following:	
Tapestry Park Charter	
North Bay Special Purpose Center	

# Inspection Summary (County-by-County)

## Bradford

Total number of schools and ancillary facilities	12
School District	
Number of school and facilities inspected	12
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	12
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	10
General Requirements	41
Means of Egress	127
Protection	66
Fire Alarm	75
Extinguishment	67
Building Services	2
Utilities	148
HVAC	1
Rubbish/Laundry Chutes	21
Operating Features	39
Outside Structure	9
No Violations Noted	12

# Inspection Summary (County-by-County)

## Brevard

Total number of schools and ancillary facilities	111
School District	
Number of school and facilities inspected	111
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	111
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	2
General Requirements	592
Means of Egress	2,710
Protection	854
Fire Alarm	269
Extinguishment	537
Building Services	12
Utilities	1,769
HVAC	59
Rubbish/Laundry Chutes	68
Operating Features	452
Outside Structure	120
No Violations Noted	2

# Inspection Summary (County-by-County)

## Broward

Total number of schools and ancillary facilities	289
School District	
Number of school and facilities inspected	289
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	289
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	30
General Requirements	3,232
Means of Egress	5,240
Protection	2,431
Fire Alarm	3,216
Extinguishment	2,983
Building Services	116
Utilities	3,243
HVAC	30
Elevator/Escalator/etc.	29
Rubbish/Laundry Chutes	213
Operating Features	932
Outside Structure	68
No Violations Noted	163
Unknown Code Violation	11

# Inspection Summary (County-by-County)

## Calhoun

Total number of schools and ancillary facilities	9
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	9
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
General Requirements	6
Means of Egress	6
Protection	2
Fire Alarm	6
Extinguishment	11
Utilities	20
Operating Features	4
Outside Structure	1
Construction/Renovation	1
No Violations Noted	6

## Charlotte

Total number of schools and ancillary facilities	25
School District	
Number of school and facilities inspected	25
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	1
Percentage inspected	4%
Total number of violations per Violation Group:	Count
General Requirements	297
Means of Egress	556
Protection	28
Fire Alarm	59
Extinguishment	137
Special Provisions	20
Building Services	9
Utilities	252
HVAC	8
Elevator/Escalator/etc.	1
Rubbish/Laundry Chutes	8
Operating Features	87
Outside Structure	7

# Inspection Summary (County-by-County)

## Citrus

Total number of schools and ancillary facilities	25
School District	
Number of school and facilities inspected	25
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	25
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	31
Means of Egress	385
Protection	1
Fire Alarm	10
Extinguishment	61
Utilities	100
HVAC	19
Elevator/Escalator/etc.	6
Rubbish/Laundry Chutes	43
Operating Features	21
Outside Structure	2
No Violations Noted	7
Percentage inspected	

# Inspection Summary (County-by-County)

## Clay

Total number of schools and ancillary facilities	42
School District	
Number of school and facilities inspected	42
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	42
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	4
General Requirements	101
Means of Egress	586
Protection	69
Fire Alarm	66
Extinguishment	193
Special Provisions	3
Building Services	13
Utilities	413
HVAC	17
Elevator/Escalator/etc.	1
Rubbish/Laundry Chutes	3
Operating Features	168
Outside Structure	76
Construction/Renovation	1
No Violations Noted	11
Unknown Code Violation	6



# Inspection Summary (County-by-County)

## Collier

Total number of schools and ancillary facilities	59
School District	
Number of school and facilities inspected	59
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	21
Percentage inspected	36%
Total number of violations per Violation Group:	Count
Imminent Hazard	9
General Requirements	73
Means of Egress	272
Protection	37
Fire Alarm	203
Extinguishment	394
Special Provisions	6
Building Services	45
Utilities	122
HVAC	3
Elevator/Escalator/etc.	1
Rubbish/Laundry Chutes	4
Operating Features	10
Outside Structure	5
Construction/Renovation	5
No Violations Noted	13
Unknown Code Violation	3

---

---

## Inspection Summary (County-by-County)

---

---

### Columbia

---

Total number of schools and ancillary facilities	15
--------------------------------------------------	----

School District

Number of school and facilities inspected	0
Percentage inspected	0%

Local Fire Authority

Number of school and facilities inspected	0
Percentage inspected	0%

Fire safety inspection reports were not received for the following:

- Challenge Learning Center
- Columbia City Elementary
- Columbia Senior high
- Columbia Superintendent's Office
- Eastside Elementary
- Five Points Elementary
- Fort White High
- Fort White Public School
- Lake City Middle
- Maintenance & Warehouse
- Melrose Elementary
- Niblack Elementary
- Richardson Middle
- Summers Elementary
- Westside Elementary

# Inspection Summary (County-by-County)

## DeSoto

Total number of schools and ancillary facilities	13
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	11
Percentage inspected	85%
Total number of violations per Violation Group:	Count
Means of Egress	76
Fire Alarm	1
Extinguishment	18
Utilities	2
HVAC	1
No Violations Noted	2
Fire safety inspection reports were not received for the following:	
Adult Education and Student Services	
Little White House	

## Dixie

Total number of schools and ancillary facilities	6
School District	
Number of school and facilities inspected	6
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	6
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	2
Means of Egress	20
Protection	7
Fire Alarm	1
Extinguishment	7
Utilities	9
HVAC	1
Outside Structure	2
No Violations Noted	5

# Inspection Summary (County-by-County)

## Duval

Total number of schools and ancillary facilities	182
School District	
Number of school and facilities inspected	182
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	179
Percentage inspected	98%
Total number of violations per Violation Group:	Count
Imminent Hazard	2
General Requirements	273
Means of Egress	1,426
Protection	92
Fire Alarm	157
Extinguishment	923
Building Services	6
Utilities	70
HVAC	21
Rubbish/Laundry Chutes	23
Operating Features	449
Outside Structure	25
No Violations Noted	1

# Inspection Summary (County-by-County)

## Escambia

Total number of schools and ancillary facilities	74
School District	
Number of school and facilities inspected	63
Percentage inspected	85%
Local Fire Authority	
Number of school and facilities inspected	26
Percentage inspected	35%
Total number of violations per Violation Group:	Count
Imminent Hazard	3
General Requirements	85
Means of Egress	400
Protection	187
Fire Alarm	214
Extinguishment	170
Special Provisions	3
Building Services	23
Utilities	336
HVAC	15
Rubbish/Laundry Chutes	1
Operating Features	177
Outside Structure	41
Construction/Renovation	2
No Violations Noted	19
Unknown Code Violation	2

Fire safety inspection reports were not received for the following:

- Beulah Academy of Science
- Capstone Academy/UCP of Northwest Florida Inc.
- Central Warehouse
- Discovery Gateway Early Learning
- Escambia Charter School
- J. E. Hall Educational Services Center
- John A. Gibson Headstart Program
- Pensacola Beach Elementary
- Roy L. Hyatt Environmental Center
- Ruby J. Gainer School for Reaching Your Dreams

# Inspection Summary (County-by-County)

## Flagler

Total number of schools and ancillary facilities	17
School District	
Number of school and facilities inspected	11
Percentage inspected	65%
Local Fire Authority	
Number of school and facilities inspected	1
Percentage inspected	6%
Total number of violations per Violation Group:	Count
General Requirements	4
Means of Egress	97
Protection	21
Fire Alarm	6
Extinguishment	28
Building Services	1
Utilities	29
HVAC	1
Outside Structure	3

Fire safety inspection reports were not received for the following:

- Carver Gymnasium
- Cornerstone Elementary
- Devereux Alternate ESE
- Heritage High
- Summit Academy

## Franklin

Total number of schools and ancillary facilities	8
School District	
Number of school and facilities inspected	7
Percentage inspected	88%
Local Fire Authority	
Number of school and facilities inspected	8
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Means of Egress	5
Fire Alarm	1
Extinguishment	2
Building Services	1

# Inspection Summary (County-by-County)

## Gadsden

Total number of schools and ancillary facilities	18
School District	
Number of school and facilities inspected	18
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	17
Percentage inspected	94%
Total number of violations per Violation Group:	Count
Imminent Hazard	4
General Requirements	253
Means of Egress	318
Protection	150
Fire Alarm	222
Extinguishment	87
Special Provisions	1
Building Services	14
Utilities	83
HVAC	69
Operating Features	8
No Violations Noted	1
Unknown Code Violation	1

## Gilchrist

Total number of schools and ancillary facilities	5
School District	
Number of school and facilities inspected	5
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	5
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
Means of Egress	2
Extinguishment	1

# Inspection Summary (County-by-County)

Glades	
Total number of schools and ancillary facilities	6
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	6
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	5

Gulf	
Total number of schools and ancillary facilities	7
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	1
Percentage inspected	14%

Fire safety inspection reports were not received for the following:

Highland View Elementary  
 Gulf/Franklin Center  
 Port St. Joe Jr./Sr. High  
 Wewahitchka Elementary  
 Wewahitchka Jr./Sr. High Maintenance



# Inspection Summary (County-by-County)

## Hamilton

Total number of schools and ancillary facilities	8
School District	
Number of school and facilities inspected	6
Percentage inspected	75%
Local Fire Authority	
Number of school and facilities inspected	8
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	2
General Requirements	8
Means of Egress	88
Protection	32
Fire Alarm	30
Extinguishment	77
Utilities	41
HVAC	1
Outside Structure	17
No Violations Noted	19

## Hardee

Total number of schools and ancillary facilities	12
School District	
Number of school and facilities inspected	12
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	12
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	6
Means of Egress	21
Protection	2
Fire Alarm	1
Extinguishment	32
Building Services	4
Utilities	59
Operating Features	8

# Inspection Summary (County-by-County)

---

---

## Hendry

---

Total number of schools and ancillary facilities	15
School District	
Number of school and facilities inspected	14
Percentage inspected	93%
Local Fire Authority	
Number of school and facilities inspected	14
Percentage inspected	93%
Total number of violations per Violation Group:	Count
Means of Egress	89
Fire Alarm	8
Extinguishment	8
Building Services	2
Utilities	39
Rubbish/Laundry Chutes	1
Outside Structure	2
Fire safety inspection reports were not received for the following:	
Clewiston Transportation	

# Inspection Summary (County-by-County)

## Hernando

Total number of schools and ancillary facilities	24
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	10
Percentage inspected	42%
Total number of violations per Violation Group:	Count
Imminent Hazard	6
Means of Egress	147
Protection	12
Fire Alarm	11
Extinguishment	40

Fire safety inspection reports were not received for the following:

- Brooksville Elementary
- District Maintenance/Plant Operations
- District Transportation
- District Warehouse
- Frank W. Springstead Senior High
- Gulf Coast Academy of Science and Technology, Inc.
- Nature Coast Tech High
- Pine Grove Elementary
- Powell Middle
- Spring Hill Elementary
- Star Education Center
- Suncoast Elementary
- West Hernando Middle
- Westside Elementary

# Inspection Summary (County-by-County)

## Highlands

Total number of schools and ancillary facilities	20
School District	
Number of school and facilities inspected	20
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	19
Percentage inspected	95%
Total number of violations per Violation Group:	Count
General Requirements	44
Means of Egress	366
Protection	57
Fire Alarm	29
Extinguishment	109
Building Services	10
Utilities	124
HVAC	23
Rubbish/Laundry Chutes	4
Operating Features	221
Outside Structure	3

# Inspection Summary (County-by-County)

## Hillsborough

Total number of schools and ancillary facilities	257
School District	
Number of school and facilities inspected	257
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	143
Percentage inspected	56%
Total number of violations per Violation Group:	Count
Imminent Hazard	7
General Requirements	1,023
Means of Egress	2,030
Protection	515
Fire Alarm	419
Extinguishment	835
Special Provisions	19
Building Services	40
Utilities	1,561
HVAC	167
Elevator/Escalator/etc.	15
Rubbish/Laundry Chutes	97
Operating Features	138
Outside Structure	47
Construction/Renovation	1
No Violations Noted	12

## Holmes

Total number of schools and ancillary facilities	10
School District	
Number of school and facilities inspected	10
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	4
Percentage inspected	40%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
Means of Egress	4
Protection	4
Fire Alarm	2
Extinguishment	2
Utilities	1
Operating Features	1

# Inspection Summary (County-by-County)

## Indian River

Total number of schools and ancillary facilities	30
School District	
Number of school and facilities inspected	30
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	30
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	2
Means of Egress	65
Protection	19
Fire Alarm	30
Extinguishment	60
Special Provisions	5
Building Services	3
Utilities	70
HVAC	5
Operating Features	15

## Jackson

Total number of schools and ancillary facilities	20
School District	
Number of school and facilities inspected	10
Percentage inspected	50%
Local Fire Authority	
Number of school and facilities inspected	13
Percentage inspected	65%
Total number of violations per Violation Group:	Count
General Requirements	3
Means of Egress	113
Protection	4
Fire Alarm	11
Extinguishment	67
Utilities	8
HVAC	2
Rubbish/Laundry Chutes	1
Operating Features	5
Construction/Renovation	1
No Violations Noted	17

Fire safety inspection reports were not received for the following:  
 Challenge for Success  
 Maintenance Yard

# Inspection Summary (County-by-County)

## Jefferson

Total number of schools and ancillary facilities	9
School District	
Number of school and facilities inspected	8
Percentage inspected	89%
Local Fire Authority	
Number of school and facilities inspected	1
Percentage inspected	11%
Total number of violations per Violation Group:	Count
Utilities	3

Fire safety inspection reports were not received for the following:

Asheville Site  
Maintenance Department  
Transportation Department

## Lafayette

Total number of schools and ancillary facilities	5
School District	
Number of school and facilities inspected	5
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	5
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	8
Means of Egress	13
Protection	1
Fire Alarm	1
Extinguishment	11
Building Services	2
Utilities	17
Rubbish/Laundry Chutes	4
No Violations Noted	16

# Inspection Summary (County-by-County)

Lake	
Total number of schools and ancillary facilities	65
School District	
Number of school and facilities inspected	60
Percentage inspected	92%
Local Fire Authority	
Number of school and facilities inspected	60
Percentage inspected	92%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
General Requirements	9
Means of Egress	310
Protection	12
Fire Alarm	110
Extinguishment	163
Building Services	5
Utilities	165
Elevator/Escalator/etc.	2
Rubbish/Laundry Chutes	27
Outside Structure	7
No Violations Noted	7
Fire safety inspection reports were not received for the following:	
Milestones Community School	
National Deaf Academy	
Rivendell Academy	
Skeen Elementary	
South Lake Elementary Charter School	



# Inspection Summary (County-by-County)

## Lee

Total number of schools and ancillary facilities	97
--------------------------------------------------	----

### School District

Number of school and facilities inspected	89
Percentage inspected	92%

### Local Fire Authority

Number of school and facilities inspected	89
Percentage inspected	92%

Total number of violations per Violation Group:	Count
Imminent Hazard	16
General Requirements	471
Means of Egress	1,390
Protection	622
Fire Alarm	596
Extinguishment	576
Special Provisions	3
Building Services	36
Utilities	630
HVAC	64
Elevator/Escalator/etc.	3
Rubbish/Laundry Chutes	12
Operating Features	107
Outside Structure	128
No Violations Noted	4
Unknown Code Violation	265

Fire safety inspection reports were not received for the following:

- Alternative Learning Center
- Excelsior Academy
- Lee Charter Academy

# Inspection Summary (County-by-County)

---

---

## Leon

---

Total number of schools and ancillary facilities	76
--------------------------------------------------	----

School District

Number of school and facilities inspected	72
Percentage inspected	95%

Local Fire Authority

Number of school and facilities inspected	74
Percentage inspected	97%

Total number of violations per Violation Group:  
Count

Imminent Hazard	4
General Requirements	62
Means of Egress	506
Protection	125
Fire Alarm	94
Extinguishment	344
Building Services	17
Utilities	77
HVAC	12
Operating Features	56
Outside Structure	1
No Violations Noted	19

Fire safety inspection reports were not received for the following:

Bond Elementary  
Odyssey Science Center

# Inspection Summary (County-by-County)

Levy	
Total number of schools and ancillary facilities	14
School District	
Number of school and facilities inspected	14
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	14
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
General Requirements	11
Means of Egress	168
Protection	29
Fire Alarm	49
Extinguishment	49
Utilities	47
HVAC	1
Rubbish/Laundry Chutes	4
Operating Features	1
Outside Structure	5
No Violations Noted	32

Liberty	
Total number of schools and ancillary facilities	7
School District	
Number of school and facilities inspected	7
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	7
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
General Requirements	25
Means of Egress	36
Protection	2
Fire Alarm	17
Extinguishment	1
Utilities	5
Operating Features	1
No Violations Noted	3

# Inspection Summary (County-by-County)

## Madison

Total number of schools and ancillary facilities	7
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	7
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	7
Means of Egress	26
Fire Alarm	5
Extinguishment	24
Building Services	2
Utilities	27
Operating Features	6

## Manatee

Total number of schools and ancillary facilities	59
School District	
Number of school and facilities inspected	56
Percentage inspected	95%
Local Fire Authority	
Number of school and facilities inspected	55
Percentage inspected	93%
Total number of violations per Violation Group:	Count
General Requirements	11
Means of Egress	120
Protection	4
Fire Alarm	9
Extinguishment	22
Building Services	1
Utilities	6
Operating Features	9
Construction/Renovation	6
No Violations Noted	23

Fire safety inspection reports were not received for the following:

Instructional Materials Center  
Manatee Superintendent's office  
R. Dan Nolan Middle

# Inspection Summary (County-by-County)

## Marion

Total number of schools and ancillary facilities	66
School District	
Number of school and facilities inspected	66
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	65
Percentage inspected	98%
Total number of violations per Violation Group:	Count
Imminent Hazard	13
General Requirements	219
Means of Egress	1,427
Protection	64
Fire Alarm	117
Extinguishment	559
Special Provisions	4
Building Services	37
Utilities	1,224
HVAC	24
Rubbish/Laundry Chutes	1
Operating Features	29
Outside Structure	8
No Violations Noted	2
Unknown Code Violation	8

# Inspection Summary (County-by-County)

## Martin

Total number of schools and ancillary facilities	26
--------------------------------------------------	----

### School District

Number of school and facilities inspected	0
Percentage inspected	0%

### Local Fire Authority

Number of school and facilities inspected	0
Percentage inspected	0%

Fire safety inspection reports were not received for the following:

- Bessey Creek Elementary
- Challenger School
- Crystal Lake Elementary
- Environmental Studies Center
- Felix A. Williams Elementary
- Hidden Oaks Elementary
- Hobe Sound Elementary
- Hope Center, The
- Indian River Adult Learning
- Indian River CC/Clark Advanced Learning Center
- Indiantown Middle
- J. D. Parker School
- Jensen Beach Elementary
- Jensen Beach High School
- Martin County Adult and Community
- Martin Senior High
- Murray Middle
- Palm City Elementary
- Pinewood Elementary
- Port Salerno Elementary (New)
- Seawind Elementary
- South Fork Senior High
- Spectrum Junior/Senior High
- Stuart Middle
- Transportation Services
- Warfield Elementary

# Inspection Summary (County-by-County)

## Miami-Dade

Total number of schools and ancillary facilities	448
School District	
Number of school and facilities inspected	403
Percentage inspected	90%
Local Fire Authority	
Number of school and facilities inspected	367
Percentage inspected	82%
Total number of violations per Violation Group:	Count
Imminent Hazard	6
General Requirements	830
Means of Egress	3,437
Protection	1,064
Fire Alarm	1,127
Extinguishment	1,466
Special Provisions	432
Building Services	134
Utilities	1,756
HVAC	56
Elevator/Escalator/etc.	37
Rubbish/Laundry Chutes	20
Operating Features	270
Outside Structure	377
Construction/Renovation	7
No Violations Noted	54

Fire safety inspection reports were not received for the following:

- Archimedean Middle Conservatory
- Aventura Elementary Charter School
- Booker T. Washington Middle
- Feinberg-Fisher Adult Community Education
- Goulds Center
- Hialeah Senior High
- José Marti Middle
- Lenora Braynon Smith Elementary
- Liberty City Charter School
- North County Charter School
- North Dade Community Charter
- North Miami Stadium
- Northeast Academy
- Palmetto Middle
- Radio Transmission Station
- Ronald W. Reagan/Doral Senior High School
- Rosa Parks Community School/Overtown
- Ryder Elementary Charter School
- Student Services and attendance Center
- Vankara Academy Charter School

# Inspection Summary (County-by-County)

## Monroe

Total number of schools and ancillary facilities	19
School District	
Number of school and facilities inspected	19
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	19
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	72
Means of Egress	322
Protection	20
Fire Alarm	33
Extinguishment	131
Building Services	2
Utilities	62
HVAC	1
Rubbish/Laundry Chutes	7
Operating Features	9
Outside Structure	2
No Violations Noted	3

## Nassau

Total number of schools and ancillary facilities	23
School District	
Number of school and facilities inspected	23
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	23
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	23
General Requirements	97
Means of Egress	100
Protection	24
Fire Alarm	89
Extinguishment	60
Special Provisions	79
Utilities	59
Rubbish/Laundry Chutes	2
Operating Features	4
Outside Structure	4
No Violations Noted	15



# Inspection Summary (County-by-County)

## Okaloosa

Total number of schools and ancillary facilities	52
--------------------------------------------------	----

### School District

Number of school and facilities inspected	49
Percentage inspected	94%

### Local Fire Authority

Number of school and facilities inspected	41
Percentage inspected	79%

Total number of violations per Violation Group:	Count
Imminent Hazard	5
General Requirements	30
Means of Egress	253
Protection	2
Fire Alarm	17
Extinguishment	120
Utilities	60
HVAC	5
Rubbish/Laundry Chutes	1
Outside Structure	5
Construction/Renovation	2
No Violations Noted	2
Unknown Code Violation	11

Fire safety inspection reports were not received for the following:

- Crestview Maintenance Shop
- Department of Juvenile Justice
- New Heights Elementary

# Inspection Summary (County-by-County)

---

---

## Okeechobee

---

Total number of schools and ancillary facilities	11
--------------------------------------------------	----

School District

Number of school and facilities inspected	0
Percentage inspected	0%

Local Fire Authority

Number of school and facilities inspected	0
Percentage inspected	0%

Fire safety inspection reports were not received for the following:

- Central Elementary
- Everglades Elementary
- New Endeavor High School
- North Elementary
- Okeechobee Freshman Campus
- Okeechobee Senior High
- Okeechobee South Elementary (new)
- Operations Center
- Osceola Middle
- Seminole Elementary
- Yearling Middle

# Inspection Summary (County-by-County)

## Orange

Total number of schools and ancillary facilities	226
School District	
Number of school and facilities inspected	224
Percentage inspected	99%
Local Fire Authority	
Number of school and facilities inspected	226
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	4
General Requirements	1,297
Means of Egress	1,399
Protection	644
Fire Alarm	528
Extinguishment	663
Special Provisions	2
Building Services	79
Utilities	1,933
HVAC	332
Elevator/Escalator/etc.	18
Rubbish/Laundry Chutes	191
Operating Features	912
Outside Structure	341
No Violations Noted	60
Unknown Code Violation	200

# Inspection Summary (County-by-County)

## Osceola

Total number of schools and ancillary facilities	56
School District	
Number of school and facilities inspected	56
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	52
Percentage inspected	93%
Total number of violations per Violation Group:	Count
General Requirements	106
Means of Egress	27
Protection	4
Fire Alarm	15
Extinguishment	11
Building Services	1
Utilities	4
Elevator/Escalator/etc.	1
Operating Features	4
Outside Structure	1
Construction/Renovation	1

# Inspection Summary (County-by-County)

## Palm Beach

Total number of schools and ancillary facilities	248
School District	
Number of school and facilities inspected	237
Percentage inspected	93%
Local Fire Authority	
Number of school and facilities inspected	237
Percentage inspected	93%
Total number of violations per Violation Group:	Count
General Requirements	261
Means of Egress	2,827
Protection	737
Fire Alarm	267
Extinguishment	1,133
Special Provisions	364
Building Services	82
Utilities	797
HVAC	155
Elevator/Escalator/etc.	2
Rubbish/Laundry Chutes	44
Operating Features	197
Outside Structure	316
No Violations Noted	124
Unknown Code Violation	2

Fire safety inspection reports were not received for the following:

- Alternative Education Administrative Center
- Hope Learning Community
- J. C. Mitchell Elementary
- Jefferson Davis Middle
- Rolling Green Elementary
- Roosevelt Elementary
- Seminole Ridge High
- Spanish Academy Charter
- West Area Secondary Intensive Transition Program
- West Technical Community High

# Inspection Summary (County-by-County)

## Pasco

Total number of schools and ancillary facilities	77
School District	
Number of school and facilities inspected	77
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	77
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	155
Means of Egress	13
Protection	9
Extinguishment	5
Utilities	2
Rubbish/Laundry Chutes	1
Operating Features	15
No Violations Noted	3

## Pinellas

Total number of schools and ancillary facilities	159
School District	
Number of school and facilities inspected	159
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	126
Percentage inspected	79%
Total number of violations per Violation Group:	Count
General Requirements	228
Means of Egress	95
Protection	17
Fire Alarm	37
Extinguishment	34
Building Services	3
Utilities	135
HVAC	1
Rubbish/Laundry Chutes	4
Operating Features	1
Outside Structure	4

# Inspection Summary (County-by-County)

## Polk

Total number of schools and ancillary facilities	123
School District	
Number of school and facilities inspected	92
Percentage inspected	75%
Local Fire Authority	
Number of school and facilities inspected	54
Percentage inspected	44%
Total number of violations per Violation Group:	Count
Imminent Hazard	24
General Requirements	52
Means of Egress	1,496
Protection	268
Fire Alarm	365
Extinguishment	673
Special Provisions	61
Building Services	30
Utilities	448
HVAC	3
Elevator/Escalator/etc.	4
Rubbish/Laundry Chutes	5
Operating Features	45
Outside Structure	17
Construction/Renovation	1
No Violations Noted	105

Fire safety inspection reports were not received for the following:

- Achievement Academy (Child Development Center)
- Apple School
- Bartow Service Facility (transportation)
- Brigham Academy
- Foundation Charter
- Hart Ridge Academy
- Lakeland Montessori
- North Central Support Services
- Oaks Middle School
- Roosevelt Academy of Applied Technology
- South Lakeland Maintenance Shop
- Star Child Development Center

# Inspection Summary (County-by-County)

## Putnam

Total number of schools and ancillary facilities	28
School District	
Number of school and facilities inspected	28
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	28
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	2
Means of Egress	103
Protection	102
Fire Alarm	34
Extinguishment	48
Building Services	22
Utilities	102
Operating Features	414
No Violations Noted	1

## St. Johns

Total number of schools and ancillary facilities	35
School District	
Number of school and facilities inspected	35
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	35
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	11
Means of Egress	72
Protection	32
Fire Alarm	39
Extinguishment	57
Building Services	1
Utilities	73
HVAC	1
Operating Features	62
Outside Structure	12
No Violations Noted	12



# Inspection Summary (County-by-County)

---

---

## St. Lucie

---

Total number of schools and ancillary facilities	43
School District	42
Number of school and facilities inspected	98%
Percentage inspected	
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
General Requirements	167
Means of Egress	271
Protection	10
Fire Alarm	2
Extinguishment	166
Building Services	6
Utilities	58
Rubbish/Laundry Chutes	1
Operating Features	50

Fire safety inspection reports were not received for the following:  
North Transportation Complex

# Inspection Summary (County-by-County)

## Santa Rosa

Total number of schools and ancillary facilities	34
School District	
Number of school and facilities inspected	30
Percentage inspected	88%
Local Fire Authority	
Number of school and facilities inspected	14
Percentage inspected	41%
Total number of violations per Violation Group:	Count
Imminent Hazard	3
General Requirements	23
Means of Egress	125
Protection	11
Fire Alarm	77
Extinguishment	87
Building Services	3
Utilities	23
HVAC	6
Operating Features	68
Outside Structure	6
Construction/Renovation	1
No Violations Noted	8

Fire safety inspection reports were not received for the following:

Navarre Senior High  
Learning Academy, The

## Sarasota

Total number of schools and ancillary facilities	52
School District	
Number of school and facilities inspected	50
Percentage inspected	96%
Local Fire Authority	
Number of school and facilities inspected	50
Percentage inspected	96%
Total number of violations per Violation Group:	Count
General Requirements	55

Fire safety inspection reports were not received for the following:

Venice Elementary  
Wings Academy Charter

# Inspection Summary (County-by-County)

## Seminole

Total number of schools and ancillary facilities	73
School District	
Number of school and facilities inspected	73
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	73
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	7
General Requirements	450
Means of Egress	724
Protection	61
Fire Alarm	218
Extinguishment	782
Special Provisions	1
Building Services	19
Utilities	351
HVAC	34
Elevator/Escalator/etc.	6
Rubbish/Laundry Chutes	4
Operating Features	115
Outside Structure	71
No Violations Noted	3

# Inspection Summary (County-by-County)

## Sumter

Total number of schools and ancillary facilities	28
School District	
Number of school and facilities inspected	28
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	24
Percentage inspected	86%
Total number of violations per Violation Group:	Count
Imminent Hazard	2
General Requirements	2
Means of Egress	311
Protection	30
Fire Alarm	30
Extinguishment	65
Building Services	2
Utilities	46
HVAC	8
Rubbish/Laundry Chutes	1
Operating Features	15
Outside Structure	3
No Violations Noted	4
Unknown Code Violation	1

## Suwannee

Total number of schools and ancillary facilities	11
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Fire safety inspection reports were not received for the following:	
Branford Bus Garage	
Branford Elementary	
Branford High School	
Douglass Center	
Superintendent's Office (Old)	
Suwannee Elementary	
Suwannee Middle	
Suwannee Primary	
Suwannee High School	
Suwannee-Hamilton Vo-Tech	
Transportation and Maintenance Center	

# Inspection Summary (County-by-County)

## Taylor

Total number of schools and ancillary facilities	10
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Fire safety inspection reports were not received for the following:	
Administration and Alternative Center	
Finance Center	
Perry Primary	
Steinhatchee School	
Taylor County Elementary (New)	
Taylor County Elementary (Old)	
Taylor County Middle	
Taylor County Senior High	
Taylor County Technical Institute	
Transportation Terminal	

## Union

Total number of schools and ancillary facilities	8
School District	
Number of school and facilities inspected	8
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	8
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Imminent Hazard	2
General Requirements	25
Means of Egress	21
Protection	22
Fire Alarm	10
Extinguishment	1
Special Provisions	1
Utilities	3
Operating Features	1
Outside Structure	1
No Violations Noted	41

# Inspection Summary (County-by-County)

## Volusia

Total number of schools and ancillary facilities	90
School District	
Number of school and facilities inspected	89
Percentage inspected	99%
Local Fire Authority	
Number of school and facilities inspected	75
Percentage inspected	83%
Total number of violations per Violation Group:	Count
General Requirements	43
Means of Egress	754
Protection	304
Fire Alarm	170
Extinguishment	795
Building Services	14
Utilities	972
HVAC	69
Operating Features	385
Outside Structure	227
No Violations Noted	131

Fire safety inspection reports were not received for the following:  
Ridgewood South

## Wakulla

Total number of schools and ancillary facilities	12
School District	
Number of school and facilities inspected	11
Percentage inspected	92%
Local Fire Authority	
Number of school and facilities inspected	12
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	16
Means of Egress	10
Protection	2
Fire Alarm	6
Extinguishment	7
Building Services	2
Utilities	9

# Inspection Summary (County-by-County)

## Walton

Total number of schools and ancillary facilities	17
School District	
Number of school and facilities inspected	16
Percentage inspected	94%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Fire safety inspection reports were not received for the following: Walton Academy, Inc.	

## Washington

Total number of schools and ancillary facilities	12
School District	
Number of school and facilities inspected	0%
Percentage inspected	0
Local Fire Authority	
Number of school and facilities inspected	2
Percentage inspected	17%
Total number of violations per Violation Group:	Count
Fire Alarm	1
Extinguishment	4
No Violations Noted	1
Fire safety inspection reports were not received for the following:	
Kate M. Smith Elementary	
Maintenance/Food/Transportation/Custodial	
Panhandle Area Education Consortium	
Rouhlac Middle	
Vernon Bus Garage	
Vernon Elementary	
Vernon Middle	
Vernon Senior High	
Washington Superintendent's Office	
Washington-Holmes Area Vocational-Technical Center	

# Inspection Summary (Community Colleges)

---

Total number of schools and ancillary facilities	136
School District	
Number of school and facilities inspected	87
Percentage inspected	64%
Local Fire Authority	
Number of school and facilities inspected	48
Percentage inspected	35%

**Brevard Community College – No reports**

**Broward Community College – No reports**

---

## Central Florida Community College

---

Total number of schools and ancillary facilities	4
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%

Fire safety inspection reports were not received for the following:  
Central Florida Community College - Citrus Campus

**Chipola Community College – No reports**



# Inspection Summary (Community Colleges)

## Daytona Community College

Total number of schools and ancillary facilities	7
School District	
Number of school and facilities inspected	7
Percentage inspected	33%
Local Fire Authority	
Number of school and facilities inspected	5
Percentage inspected	0%
Total number of violations per Violation Group:	Count
Means of Egress	42
Protection	15
Fire Alarm	29
Extinguishment	40
Building Services	3
Utilities	128

## Edison College – No reports

## Florida Community College at Jacksonville

Total number of schools and ancillary facilities	12
School District	
Number of school and facilities inspected	8
Percentage inspected	78%
Local Fire Authority	
Number of school and facilities inspected	8
Percentage inspected	78%
Total number of violations per Violation Group:	Count
Means of Egress	6
Protection	1
Fire Alarm	6
Extinguishment	2
Utilities	1
Outside Structure	6

# Inspection Summary (Community Colleges)

## Florida Keys Community College

Total number of schools and ancillary facilities	1
School District	
Number of school and facilities inspected	1
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
Imminent Hazard	1

## Gulf Coast Community College

Total number of schools and ancillary facilities	3
School District	
Number of school and facilities inspected	3
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	3
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Means of Egress	84
Protection	22
Fire Alarm	4
Extinguishment	16
Utilities	19

# Inspection Summary (Community Colleges)

## Hillsborough Community College

Total number of schools and ancillary facilities	6
School District	
Number of school and facilities inspected	6
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
Means of Egress	1

## Indian River Community College

Total number of schools and ancillary facilities	5
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%

## Lake-Sumter Community College

Total number of schools and ancillary facilities	3
School District	
Number of school and facilities inspected	1
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
General Requirements	2
Means of Egress	2
Protection	1
Fire Alarm	2
Utilities	2
Elevator/Escalator/etc.	2

**Manatee Community College – No reports**

# Inspection Summary (Community Colleges)

## Miami-Dade Community College

Total number of schools and ancillary facilities	1
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	1
Percentage inspected	100%
Total number of violations per Violation Group:	Count
General Requirements	4
Means of Egress	8
Special Provisions	1
Utilities	1
Outside Structure	1

North Florida Community College – No reports

## Okaloosa-Walton Community College

Total number of schools and ancillary facilities	6
School District	
Number of school and facilities inspected	0
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%

## Orange County Community College

Total number of schools and ancillary facilities	7
School District	
Number of school and facilities inspected	7
Percentage inspected	50%
Local Fire Authority	
Number of school and facilities inspected	7
Percentage inspected	50%
Total number of violations per Violation Group:	Count
General Requirements	2

# Inspection Summary (Community Colleges)

## Palm Beach Community College

Total number of schools and ancillary facilities	6
School District	
Number of school and facilities inspected	6
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
Imminent Hazard	1
General Requirements	1
Means of Egress	35
Protection	1
Fire Alarm	2
Extinguishment	10
Utilities	14

## Pasco-Hernando Community College

Total number of schools and ancillary facilities	4
School District	
Number of school and facilities inspected	4
Percentage inspected	50%
Local Fire Authority	
Number of school and facilities inspected	4
Percentage inspected	50%
Total number of violations per Violation Group:	Count
General Requirements	4
Means of Egress	24
Protection	2
Extinguishment	7
Building Services	1
Utilities	5
HVAC	4
Rubbish/Laundry Chutes	1
Operating Features	1
Outside Structure	1

# Inspection Summary (County-by-County)

## Pensacola Junior College

Total number of schools and ancillary facilities	5
School District	
Number of school and facilities inspected	2
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	100%
Total number of violations per Violation Group:	Count
Means of Egress	3
Protection	3
Fire Alarm	1
Utilities	5

## Polk Community College

Total number of schools and ancillary facilities	2
School District	
Number of school and facilities inspected	2
Percentage inspected	0%
Local Fire Authority	
Number of school and facilities inspected	2
Percentage inspected	0%

# Inspection Summary (County-by-County)

## St. Johns River Community College

Total number of schools and ancillary facilities	4
School District	
Number of school and facilities inspected	3
Percentage inspected	50%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
General Requirements	5
Means of Egress	7
Protection	2
Fire Alarm	14
Extinguishment	7
Utilities	1
HVAC	1
Rubbish/Laundry Chutes	5

## St. Petersburg College

Total number of schools and ancillary facilities	12
School District	
Number of school and facilities inspected	12
Percentage inspected	20%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
General Requirements	1
Means of Egress	7
Protection	2
Extinguishment	5
Building Services	1
Utilities	1

# Inspection Summary (County-by-County)

## Santa Fe Community College

Total number of schools and ancillary facilities	6
School District	
Number of school and facilities inspected	6
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
Means of Egress	5
Protection	1
Fire Alarm	3
Extinguishment	13
Building Services	5
Utilities	11

## Seminole Community College

Total number of schools and ancillary facilities	3
School District	
Number of school and facilities inspected	1
Percentage inspected	33%
Local Fire Authority	
Number of school and facilities inspected	0
Percentage inspected	0%
Total number of violations per Violation Group:	Count
No Violations Noted	1

## South Florida Community College

Total number of schools and ancillary facilities	9
School District	
Number of school and facilities inspected	9
Percentage inspected	100%
Local Fire Authority	
Number of school and facilities inspected	9
Percentage inspected	100%
Total number of violations per Violation Group:	Count
No Violations Noted	1

## Tallahassee Community College – No reports



---

**For a Complete Report on Each  
School or Community College  
Visit our website  
<http://www.fldfs.com/SFM/>**

---